



MINIMA ROUND FIXED (1249013)



MINIMA SQUARE FIXED (1249014)



DOWNLIGHTS

MINIMA

ZONES 1 2 3


ROUND FIXED		LAMP	WATT	INPUT	K	CRI	Lm	IP	C_ASS					
	1249013 (5770)	Integral LED	6.5W	Mains 230V	2700	80	525	65		Ø86	✓	43°	✓	✓
	1249012 (5745) 1249017 (5793)	GU10 LED▼	6W max	–	–	–	–	65		Ø76	✓	–	–	–
SQUARE FIXED		LAMP	WATT	INPUT	K	CRI	Lm	IP	C_ASS					
	1249014 (5771)	Integral LED	6.5W	Mains 230V	2700	80	538	65		W: 86 H: 86	✓	45°	✓	✓
	1249018 (5794)	GU10 LED▼	6W max	–	–	–	–	65		Ø76	✓	–	–	–



1249013



1249012 | 1249017



1249014



1249018

⚡ Our fire rated downlights comply with all the latest building regulations: Part B – Fire Safety. The downlights have been tested to provide a minimum of 90 minutes fire protection (BS 476: part 21).

▼ LAMP/INPUT SOURCE EXCLUDED, SEE PAGE 634.
/ La lampe/source d'entrée exclu, voir page 634.
/ La lampadina/input esclusi a pagina 634 / Das Leuchtmittel ist ausgeschlossen. Sie auf Seite 634.



MINIMA SQUARE FIXED (1249007)



MINIMA SQUARE ADJUSTABLE (1249020)



DOWNLIGHTS

MINIMA

SQUARE FIXED



NEW	MW	1249007 (5738)	MB	1249019 (5795)
	MW	1249011 (5742)		

LAMP	WATT	CLASS			
GU10 LED ▼	6W max	⊕	W:92 L:92	✓	-
GU10 LED ▼	6W max	⊕	W:92 L:92	✓	✓

SQUARE ADJUSTABLE

NEW	MW	1249006 (5737)	MB	1249020 (5796)
	MW	1249009 (5740)		

GU10 LED ▼	6W max	⊕	W:92 L:92	✓	-
GU10 LED ▼	6W max	⊕	W:92 L:92	✓	✓



⚡ Our fire rated downlights comply with all the latest building regulations: Part B - Fire Safety. The downlights have been tested to provide a minimum of 90 minutes fire protection (BS 476: part 21).

▼ LAMP/INPUT SOURCE EXCLUDED, SEE PAGE 634. / La lampe/source d'entrée exclu, voir page 634. / La lampadina/input esclusi a pagina 634 / Das Leuchtmittel ist ausgeschlossen. Sie auf Seite 634.